

Telephone:08473-252101

**Karnataka State Fire & Emergency Services Department**



Office of the District Fire Officer  
Karnataka State Fire & Emergency Services  
Yadagire Fire Station , Yadagiri-585201



C.No:43/FSR/DFO//YDG/2025

Date:03/12/2025

ANNEXURE-1

(Up to 14.99 meters in height)

Group B Educational Building

NBC-2016, Part-4, Table 7 (11) 3. 1.3 Group B Educational Buildings Sub divisions B1 & B2. (These condition are indicative and not inclusive all relevant provisions related to fire and life safety «of NBC 2016 are mandatory)

To,

THEPRESIDENT  
D. DEVARAJ URS HPS AND HS SCHOOL  
CHITTAPUR ROAD YADGIRI  
TQ, DIST-YADAGIRI-585202.

Sir,

**Sub:** - Issuing of "Fire Safety recommendation Certificate" to D. DEVARAJ URS H.P.S and H.S School near mini Vidansouda (muddanal cross) Chittapur road Yadgiri Tq/Dist-Yadgiri-585202.Under D. DEVARAJ Urs Educatonal Seva Society ® Saidapur Tq/dist/Yadagiri.-585202.

**Ref:** -1).Applicant letter date:-20-11-2025.

\*\*\*\*\*

With reference to the subject above citedThe premises of "D. DEVARAJ URS HPS AND HS SCHOOL, near mini vidansouda (muddanal cross) chittapur road Yadagiri. Tq/Dist-Yadgiri-585202. Under D. DEVARAJ Urs Educatonal Seva Society ® Saidapur, Tq/Dist-Yadagiri was inspected by District Fire Officer Yadagiri on 29-11-2025 With respect to fire prevention, firefighting and evacuation measures and the details are as follows.

**A. Details of the Building/Premises:-**

01.	Name and Address of the applicant.	:	The principal Unaided D. Devaraj Urs IIPS & HS Yadagir
02.	Name and Address of the premises.	:	D. DEVARAJ URS IIPS AND IIS SCHOOL, near mini vidansouda (muddanal cross) Chittapur road Yadagiri. Tq/Dist-Yadgiri-585202. Under : D. DEVARAJ Urs Educatonal Seva Society ® Saidapur, Tq/Dist-Yadagiri -585202
03.	Name and Address of the Building owner.	:	The president D. DEVARAJ Urs Educatonal Seva Society ® Saidapur, Tq/Dist-Yadagiri -585202
04.	Number of Buildings	:	01
05.	Number of floors	:	Ground +2 upper floors.
06.	Floor-wise details of occupancy :-		



	<b>Ground Floor</b>	:	Digital Class rooms-01 no, Class rooms-11 no's, Medical room-01 no, Admin room-01 no, Principal room-01, Strong room-01, Staff room-02, Store room-01.
	<b>1<sup>st</sup> Floor</b>	:	Physics Lab-01, Class rooms-02 no's, Multipurpose room-03 no's, Library room-01 no, Staff room-01 no, Biology Lab-01 & Chemistry Lab -01
	<b>2<sup>nd</sup> floor</b>	:	Class Room-15 No's,
07	Height of the building	:	11.00.Mtrs.
08	Site area	:	01 acre 00 guntas
09	Built-up area of each floor :-		
	<b>Ground Floor</b>	:	1518.10 sq.mtrs
	<b>First Floor</b>	:	1518.10 sq.mtrs
	<b>Second floor</b>	:	1518.10 sq.mtrs
10	Total built-up area	:	<b>4554.30Sq.Mtr.</b>
11	Surrounding properties:-		
	North(Front)	:	Open site.
	South(Rear)	:	Open site.
	East(Side)	:	D. Devaraj Urs ICSE School.
	West(Side)	:	Open site.
12.	Set back area available around the Building:-		
	East	:	08.00 Meter
	West	:	00.00 Meter
	North	:	07.00 Meter
	South	:	06.00Meter
			Recommended: To provide as per Local Zonal Regulations.

**B. On inspection of this Educational premises, the following fire prevention, firefighting and evacuation measures are recommended & are considered absolutely essential from fire safety point of view:-**

Sl. No. [01]	Details [02]	Existing [03]	Recommendations [04]
01	Accessibility to Premises.	The premises are accessible from 06.00 mtrs. wide Road Located on Western Side.	-
02	No of entrances.	01 No. of Entrance / Exits Width of 06.00 Mtrs. With arch height- 05.00 mtrs	-
03	No. of staircases available	No of staircase	: 02 nos
		Width of staircase	: 01.20 mtrs
			Adequate.



			each
		Width of treads	: 27 Cms each
		Height of risers	: 15cms each
		No of riser per flight	: 09nos each
		Height of handrails	: 00.90 Mtrs each
		Head room Clearance	02.80 Mtrs each
04	Fire extinguisher	Provided 02 no's ABC Fire Extinguisher each of 4 kg capacity. 03 no's DCP Fire Extinguisher of 06 kg capacity.	<ol style="list-style-type: none"> <li>1) 01 no's ABC Fire Extinguisher each of 6 kg capacity in Should Be Located as Available Within 15 mtrs Radius in each Floor.</li> <li>2) 01 no's CO2 Fire Extinguisher of 4.5 kg capacity Should Be Provided Near Each Electrical Panel Board and Electrical Room Switch Board,</li> <li>3) 01 No Mechanical Foam Extinguisher of 09 liter Capacity and 01 ABC type Extinguisher of 06 kg Capacity Should isprovided near Diesel Generator.</li> <li>4) 01 DCP Extinguisher of 04 kg Capacity Should isprovided in the kitchen if provided For the purpose of mid-daymeal. (All the Extinguishers Suggested above should be with B.I.S Marking and Should be Located at an easily accessible Position Without Obstructing the normal Passage and maintained Periodically)</li> </ol>
05	Hose reel hose system.	<b>Recommended to provide</b> Hose Reel Hose System near staircase.(One Hose reel Hose System for every 1000 Sq. Mtrs) The hose reel hose	complied



		of min 19mm in size & 30 mtrs Length with drum and 01 No's delivery Hose pipes of adequate length to reach the farthest point of each floor should be provided with shut off branch having a nozzle of 5 mm size. The hose reel hose should be connected at each landing by means of an adaptor	
06	Terrace tank over respective tower terrace.	Provided Provided 4000liters capacity Syntax.	<b><u>Recommended to provide</u></b> The system should be connected to an overhead tank of 10,000 Letters capacity and further if basement provided the tank capacity shall be increased to 10,000 Letters capacity. <b>(The water tank should be kept exclusively for firefighting purpose)</b> <b>Note:</b> If the existing building is not capable of sustaining the weight of 5,000/10,000 Letters tank capacity provision shall be made to provide water tank on the side of the building with support from ground level by providing RCC column structure or MS Column structure. If there is no option to provide even the above mentioned overhead tank provision shall be made to provide Underground Tank with submersible pump of 5-7 HP capacity.
07	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup>	Provided booster pump 03 HP Capacity.	<b><u>Recommended to provide</u></b> Booster pumps of capacity 450 LPM or 5 HP Capacity. <b>(Further the system should be connected to an alternative source of power supply)</b>
08	Diesel generators.	Not Provided.	<b><u>Recommended to provide</u></b> Diesel Generator of 15 KVA capacity should be provided to supply alternative power for staircase lighting, corridor lighting



			and lifts, etc., in the event of failure of electricity supply in the building.
09	Terrace tank.	Not Provided.	<b><u>Recommended to provide</u></b> To Provide Over Head Tank of 10,000 Ltrs for Fire Fighting purpose.
10	Escape routes	<u>Recommended to provide</u> Direction in which the students have it move in the event of an emergency should be displayed in the corridor in each floor during evocation.	complied
11	Fire order (Fire Safety Plans)	Recommended a notice board/Fire safety plan indicating the details of actions to be taken in case of emergency shall be displayed near each staircase landings with the telephone numbers of our <b><u>Yadagiri Fire Station</u></b> 08473-252101 and 108, or 112 telephone numbers of nearest Ambulance Service and Police Station.	Complied
12	No Smoking Board	Not Displayed	COPTA Sec-4 direction- No Smoking area, smoking here is an offence- board should be written in English & Kannada both language shall be prominently displayed at inside the entry/exit of the each floor.
13	Fire Siren	Not Installed	A fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.
14	Nominate one fire Nodal officer	-	A fire nodal officer shall be nominated either from teaching or no teaching staff.
15	Firefighting training.	Not Obtained	At-least 40% of School Staff should be got trained in basic firefighting at R.A.Mundkur fire & Emergency Services Academy, Bannerughatta road, Bangalore within 3 months



		or at an early date.
--	--	----------------------


15) Fire Precautionary Measures:

- 1) Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, and laboratory, and electrical cum panel premises.
- 2) Accumulation of combustible waste in and around the premises should be avoided.
- 3) The exit ways shall be always kept clear without any Obstruction.
- 4) Liquefied petroleum gas should not be stored in the building.
- 5) The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- 6) During the class hours the class room doors shall not be locked from inside to outside.
- 7) As per Honorable Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on 14<sup>th</sup> of every year by conducting fire safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "**Fire Safety Recommendation**" to D. DEVARAJ URS HPS AND HS SCHOOL, near mini vidansouda (muddanal cross) chittapur road yadgiri tq, dist-yadagiri-585202 Under D. DEVARAJ Urs Educatonal seva society @ saidapur Tq, Dist-Yadagiri-585202. Subjected to condition and compliance of the above recommendations in column-4 of serial-B within 03 months and compliance to the undersigned.

This "**Fire Safety Recommendation**" is valid for only one year from the date of issue and is renewable.

Yours Faithfully

  
 District Fire Officer <sup>03/12/2025</sup>  
 Karnataka Fire & Emergency Services  
 Yadgir Dist, Yadagiri - 585201